



Evaluation Listing CCMC 13250-L

MASTERFORMAT: 05 12 00.02
Issued: 2006-06-30
Re-evaluated: 2012-10-19
Re-evaluation due: 2015-06-30

CA-200, CA-300 and CA-300-40 Series Adjustable Columns

1. Evaluation

These product series conform to CAN/CGSB-7.2-94. The maximum extension for each series is shown in the following table:

Model	Maximum Extension (mm)
CA-200 Series	3073.4
CA-300 Series	3150
CA-300-40 Series	3150

2. Description

The products are Type 2, adjustable, single-tubed steel columns. The main dimensions of each model is outlined in the following table:

Model	Tube	
	Outer Diameter (mm)	Wall Thickness (mm)
CA-200 Series	76	3.0
CA-300 Series	89	3.0
CA-300-40 Series	89	5.5

The top and bottom plates are manufactured in several forms and dimensions meeting the minimum requirements of CAN/CGSB-7.2. See the Preface for details.

3. Standard and Regulatory Information

See the [Preface](#) and the standard for explanation.



Listing Holder: The Akron Products Company
10721 South Water Street
Meadville, PA 16335
U.S.A.
Tel: 330-576-1750
Fax: 330-576-1755
E-mail: info@akronproducts.com
Web: www.akronproducts.ca

Plant(s): Meadville, PA, U.S.A.

This Listing is issued by the Canadian Construction Materials Centre, a program of NRC Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to http://www.nrc-cnrc.gc.ca/eng/solutions/advisory/ccmc_index.html, or contact the Canadian Construction Materials Centre, NRC Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.





Evaluation Listing CCMC 13269-L

MASTERFORMAT: 05 12 00.02
Issued: 2007-01-08
Re-evaluated: 2010-07-13
Revised: 2011-05-18
Re-evaluation due: 2013-01-08

CA-2, CA-3, CA-84, and CA-108 Adjustable Columns

1. Evaluation

These products conform to CAN/CGSB-7.2-94. The maximum allowable load at the maximum extension is shown in the following table:

Model	Maximum Extension (mm)	Maximum Allowable Load(1)(kN)
CA-2	1 400	57.8
CA-3	910	65.6
CA-84	2 540	36.8
CA-108	2 760	38.5

(1) The maximum allowable load refers to the maximum allowable working load as presented in CAN/CGSB-7.2, Section 5.8.

2. Description

The products are Type 1, telescopic, adjustable, double-tubed steel columns. The main dimensions of each model is outlined in the following table:

Model	Outer Tube		Inner Tube	
	Outer Diameter (mm)	Wall Thickness (mm)	Outer Diameter (mm)	Wall Thickness (mm)
CA-2	71.5	3	63.5	3
CA-3	71.5	3	63.5	3
CA-84	71.5	3	63.5	3
CA-108	71.5	3	63.5	3

The top and bottom plates are manufactured in several forms and dimensions meeting the minimum requirements of CAN/CGSB-7.2. See the Preface for details.

3. Standard and Regulatory Information



Report Holder: The Akron Products Company
10721 South Water Street
Meadville, PA, 16335
U.S.A.
Tel: 330-576-1750
Fax: 330-576-1755
E-mail: info@akronproducts.com
Web: www.akronproducts.ca

Plants: Meadville, PA, U.S.A.

This Report is issued by the Canadian Construction Materials Centre, a program of the Institute for Research in Construction at the National Research Council of Canada. The Report must be read in the context of the entire CCMC Registry of Product Evaluations, including, without limitation, the introduction therein which sets out important information concerning the interpretation and use of CCMC Evaluation Reports.

Readers must confirm that the Report is current and has not been withdrawn or superseded by a later issue. Please refer to <http://www.nrc-cnrc.gc.ca/eng/services/irc/ccmc.html>, or contact the Canadian Construction Materials Centre, Institute for Research in Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Report are directed to those who have the appropriate degree of experience to use and apply its contents. This Report is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Report. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.

